

**CHATHAM WATER SYSTEM**  
**Public Water Supply ID: LA1049004**  
**Consumer Confidence Report**

# 2023 CCR

**Additional  
Information and  
Electronic Copies  
can be found at  
[www.ldh.la.gov/ccr](http://www.ldh.la.gov/ccr)**

What you need to do:

Review base report (numbered pages) for errors. If you are a surface water system, you must insert the turbidity data.

Distribute completed report to your customers as outlined on the CCR Certification of Distribution Form no later than June 30, 2024.

A completed CCR Certification of Distribution Form including a copy of the final CCR report shall be submitted to the State at the address provided on the form no later than September 30, 2024.

**If submitting CCR Electronically by posting on a website, be aware of LAC 51:XII.403.C – Community water systems shall include their final letter grade and score in their annual Consumer Confidence Report (a.k.a. Annual Water Quality Report) that is posted on the water system website. A statement like below must be added to the CCR notifying consumers of the water system grade.**

Our water system grade is a “fill in grade here”. Our water system report card can be found at “insert water system website link”.

**UCMR5-Water systems are required to distribute results for the unregulated contaminant monitoring rule (UCMR). If you have collected samples and received results, you may insert that data into the CCR to satisfy the notification requirement. The average of all results and the range of results at with the contaminant was detected.**

**Notes:**

This page is not part of your CCR; it is only the instruction page. The pages that are numbered

in the upper right hand corner are the report pages.

This page intentionally left blank

# The Water We Drink

## CHATHAM WATER SYSTEM

Public Water Supply ID: LA1049004

We are pleased to present to you the Annual Water Quality Report for the year 2023. This report is designed to inform you about the quality of your water and services we deliver to you every day (Este informe contiene información muy importante sobre su agua potable. Tradúzcalo o hable con alguien que lo entienda bien). Our constant goal is to provide you with a safe and dependable supply of drinking water. We want you to understand the efforts we make to continually improve the water treatment process and protect our water resources. We are committed to ensuring the quality of your water.

Our water source(s) are listed below:

Source Name	Source Water Type
WELL #2	Ground water
WELL #3 BY CHATHAM CEMETERY	Ground water

The sources of drinking water (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of land or through the ground, it dissolves naturally-occurring minerals and, in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activity. Contaminants that may be present in source water include:

Microbial Contaminants - such as viruses and bacteria, which may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife.

Inorganic Contaminants - such as salts and metals, which can be naturally-occurring or result from urban stormwater runoff, industrial, or domestic wastewater discharges, oil and gas production, mining, or farming.

Pesticides and Herbicides - which may come from a variety of sources such as agriculture, urban stormwater runoff, and residential uses.

Organic Chemical Contaminants - including synthetic and volatile organic chemicals, which are by-products of industrial processes and petroleum production, and can also come from gas stations, urban stormwater runoff, and septic systems.

Radioactive Contaminants - which can be naturally-occurring or be the result of oil and gas production and mining activities.

A Source Water Assessment Plan (SWAP) is now available from our office. This plan is an assessment of a delineated area around our listed sources through which contaminants, if present, could migrate and reach our source water. It also includes an inventory of potential sources of contamination within the delineated area, and a determination of the water supply's susceptibility to contamination by the identified potential sources. According to the Source Water Assessment Plan, our water system had a susceptibility rating of 'MEDIUM'. If you would like to review the Source Water Assessment Plan, please feel free to contact our office.

In order to ensure that tap water is safe to drink, EPA prescribes regulations which limit the amount of certain contaminants in water provided by public water systems. Food and Drug Administration regulations establish limits for contaminants in bottled water which must provide the same protection for public health. We want our valued customers to be informed about their water utility. If you have any questions about this report, want to attend any scheduled meetings, or simply

want to learn more about your drinking water, please contact GREGORY C. HARRIS at 318-249-2541.

If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. CHATHAM WATER SYSTEM is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at <http://www.epa.gov/safewater/lead>.

The Louisiana Department of Health and Hospitals - Office of Public Health routinely monitors for constituents in your drinking water according to Federal and State laws. The tables that follow show the results of our monitoring during the period of January 1st to December 31st, 2023. Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that water poses a health risk.

In the tables below, you will find many terms and abbreviations you might not be familiar with. To help you better understand these terms, we've provided the following definitions:

Parts per million (ppm) or Milligrams per liter (mg/L) – one part per million corresponds to one minute in two years or a single penny in \$10,000.

Parts per billion (ppb) or Micrograms per liter (ug/L) – one part per billion corresponds to one minute in 2,000 years, or a single penny in \$10,000,000.

Picocuries per liter (pCi/L) – picocuries per liter is a measure of the radioactivity in water.

Treatment Technique (TT) – an enforceable procedure or level of technological performance which public water systems must follow to ensure control of a contaminant.

Action level (AL) – the concentration of a contaminant that, if exceeded, triggers treatment or other requirements that a water system must follow.

Maximum contaminant level (MCL) – the “Maximum Allowed” MCL is the highest level of a contaminant that is allowed in drinking water. MCL's are set as close to the MCLG's as feasible using the best available treatment technology.

Maximum contaminant level goal (MCLG) – the “Goal” is the level of a contaminant in drinking water below which there is no known or expected risk to human health. MCLG’s allow for a margin of safety.

Maximum residual disinfectant level (MRDL) – The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.

Maximum residual disinfectant level goal (MRDLG) – The level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.

Level 1 assessment – A study of the water system to identify potential problems and determine (if possible) why total coliform bacteria have been found in our water system.

Level 2 Assessment – A very detailed study of the water system to identify potential problems and determine (if possible) why an E. coli MCL violation has occurred and/or why total coliform bacteria have been found in our water system on multiple occasions.

During the period covered by this report we had the below noted violations.

Compliance Period	Analyte	Type
-------------------	---------	------

Our water system tested a minimum of 2 samples per month in accordance with the Total Coliform Rule for microbiological contaminants. With the microbiological samples collected, the water system collects disinfectant residuals to ensure control of microbial growth.

Disinfectant	Date	HighestRAA	Unit	Range	MRDL	MRDLG	Typical Source
--------------	------	------------	------	-------	------	-------	----------------

In the tables below, we have shown the regulated contaminants that were detected. Chemical Sampling of our drinking water may not be required on an annual basis; therefore, information provided in this table refers back to the latest year of chemical sampling results.

The State of Louisiana regularly monitors source water per State and Federal Regulations. Treated water samples are monitored to further evaluate compliance.

Source Water Regulated Contaminants	Collection Date	Highest Value	Range	Unit	MCL	MCLG	Typical Source
CYANIDE	9/20/2021	6.3	0 - 6.3	ppb	200	200	Discharge from steel/metal factories; Discharge from plastic and fertilizer factories
FLUORIDE	9/20/2021	0.5	0.3 - 0.5	ppm	4	4	Erosion of natural deposits; Water additive which promotes strong teeth; Discharge from fertilizer and aluminum factories

Source Water Radiological Contaminants	Collection Date	Highest Value	Range	Unit	MCL	MCLG	Typical Source
GROSS BETA PARTICLE ACTIVITY	9/20/2021	1.18	0 - 1.18	pCi/l	50	0	Decay of natural and man-made deposits. Note: The gross beta particle activity MCL is 4 millirems/year annual dose equivalent to the total body or any

							internal organ. 50 pCi/L is used as a screening level.
--	--	--	--	--	--	--	--

Lead and Copper	Date	90TH Percentile	Range	Unit	AL	Sites Over AL	Typical Source
COPPER, FREE	2019 - 2022	0.1	0.1 - 0.2	ppm	1.3	0	Corrosion of household plumbing systems; Erosion of natural deposits; Leaching from wood preservatives
LEAD	2019 - 2022	7	1 - 7	ppb	15	0	Corrosion of household plumbing systems; Erosion of natural deposits

Disinfection Byproducts	Sample Point	Period	Highest LRAA	Range	Unit	MCL	MCLG	Typical Source
TOTAL HALOACETIC ACIDS (HAA5)	100 LELAND PARDUE RD	2023	10	8 - 11.7	ppb	60	0	By-product of drinking water disinfection
TOTAL HALOACETIC ACIDS (HAA5)	1211 WILDER AVE	2022 - 2023	6	6.4	ppb	60	0	By-product of drinking water disinfection
TOTAL HALOACETIC ACIDS (HAA5)	211 SALISBURY	2022 - 2023	12	10.8	ppb	60	0	By-product of drinking water disinfection
TOTAL HALOACETIC ACIDS (HAA5)	3877 HWY 146	2022 - 2023	12	9.9 - 15.8	ppb	60	0	By-product of drinking water disinfection
TOTAL HALOACETIC ACIDS (HAA5)	LA-4 & MARIAH RD	2023	10	9.2 - 10.2	ppb	60	0	By-product of drinking water disinfection
TTHM	100 LELAND PARDUE RD	2023	54	33.5 - 65.3	ppb	80	0	By-product of drinking water chlorination
TTHM	1211 WILDER AVE	2022 - 2023	26	30.8	ppb	80	0	By-product of drinking water chlorination
TTHM	211 SALISBURY	2022 - 2023	70	58.1	ppb	80	0	By-product of drinking water chlorination
TTHM	3877 HWY 146	2022 - 2023	71	46 - 91.6	ppb	80	0	By-product of drinking water chlorination
TTHM	LA-4 & MARIAH RD	2023	61	47.5 - 81.6	ppb	80	0	By-product of drinking water chlorination

Source Secondary Contaminants	Collection Date	Highest Value	Range	Unit	SMCL
CHLORIDE	9/20/2021	155	16 - 155	MG/L	250
PH	9/20/2021	9.24	9.16 - 9.24	PH	8.5
SULFATE	9/20/2021	25	5 - 25	MG/L	250

Treated Secondary Contaminants	Collection Date	Highest Value	Range	Unit	SMCL
IRON	4/19/2023	0.01	0.01	MG/L	0.3

Unresolved significant deficiencies that were identified during a survey done on the water system are shown below.



Date Identified	Facility	Code	Activity	Due Date	Description
7/25/2023	BOOSTER PUMPS - NEW HOPE SITE	20OT101	GWR ADDRESS TT45 DEFICIENCIES	11/4/2023	LAC 51:XII.319.D.24 - System shall ensure that no critical water system component is in poor condition or defective.;
7/25/2023	BOOSTER PUMPS - NEW HOPE SITE	20OT101	GWR APPROVED CORRECTIVE ACTION PLAN	2/2/2024	LAC 51:XII.319.D.24 - System shall ensure that no critical water system component is in poor condition or defective.;
7/25/2023	GROUND STORAGE TANK - NEW HOPE SITE	20ST14	GWR ADDRESS TT45 DEFICIENCIES	11/4/2023	LAC 51:XII.319.D.14 and 337.C - Any vent, overflow, or water level control gauge provided on tanks or other structures containing water for any potable water supply shall be constructed so as to prevent the entrance of birds, insects, dust or other contaminating material. Openings or vents shall face downward and shall be not less than 2 feet above the floor of a pump room, the roof or cover of a tank, the ground surface or the surface of other water supply structures.;
7/25/2023	GROUND STORAGE TANK - NEW HOPE SITE	20ST14	GWR APPROVED CORRECTIVE ACTION PLAN	2/2/2024	LAC 51:XII.319.D.14 and 337.C - Any vent, overflow, or water level control gauge provided on tanks or other structures containing water for any potable water supply shall be constructed so as to prevent the entrance of birds, insects, dust or other contaminating material. Openings or vents shall face downward and shall be not less than 2 feet above the floor of a pump room, the roof or cover of a tank, the ground surface or the surface of other water supply structures.;
7/25/2023	PRECHLORINATION - WELL #2 & #3	20MG58	GWR ADDRESS TT45 DEFICIENCIES	11/4/2023	LAC 51:XII.319.D.2 and LAC 51:XII.135.A - Dedicated standby power shall be provided by any community water supply and any non-community water supply serving a hospital so that water can be treated and/or pumped to the distribution svstem during power outages

					to meet the average daily demand during the month of maximum water use. A standby power supply shall be provided through a dedicated portable or in-place auxiliary power of adequate supply and connectivity.;
7/25/2023	PRECHLORINATION - WELL #2 & #3	20MG58	GWR APPROVED CORRECTIVE ACTION PLAN	2/2/2024	LAC 51:XII.319.D.2 and LAC 51:XII.135.A - Dedicated standby power shall be provided by any community water supply and any non-community water supply serving a hospital so that water can be treated and/or pumped to the distribution system during power outages to meet the average daily demand during the month of maximum water use. A standby power supply shall be provided through a dedicated portable or in-place auxiliary power of adequate supply and connectivity.;
7/25/2023	TREATMENT PLANT - NEW HOPE BOOSTER SITE	20MG58	GWR ADDRESS TT45 DEFICIENCIES	11/4/2023	LAC 51:XII.319.D.2 and LAC 51:XII.135.A - Dedicated standby power shall be provided by any community water supply and any non-community water supply serving a hospital so that water can be treated and/or pumped to the distribution system during power outages to meet the average daily demand during the month of maximum water use. A standby power supply shall be provided through a dedicated portable or in-place auxiliary power of adequate supply and connectivity.;
7/25/2023	TREATMENT PLANT - NEW HOPE BOOSTER SITE	20MG58	GWR APPROVED CORRECTIVE ACTION PLAN	2/2/2024	LAC 51:XII.319.D.2 and LAC 51:XII.135.A - Dedicated standby power shall be provided by any community water supply and any non-community water supply serving a hospital so that water can be treated and/or pumped to the distribution system during power outages

					to meet the average daily demand during the month of maximum water use. A standby power supply shall be provided through a dedicated portable or in-place auxiliary power of adequate supply and connectivity.;
7/25/2023	TREATMENT PLANT - NEW HOPE BOOSTER SITE	20OT101	GWR ADDRESS TT45 DEFICIENCIES	11/4/2023	LAC 51:XII.319.D.24 - System shall ensure that no critical water system component is in poor condition or defective.;
7/25/2023	TREATMENT PLANT - NEW HOPE BOOSTER SITE	20OT101	GWR APPROVED CORRECTIVE ACTION PLAN	2/2/2024	LAC 51:XII.319.D.24 - System shall ensure that no critical water system component is in poor condition or defective.;
7/25/2023	WATER WELL - NEW HOPE SITE	20SW17	GWR ADDRESS TT45 DEFICIENCIES	11/4/2023	LAC 51:XII.319.D.13 and 331.A - Abandoned water wells and well holes shall be plugged in accordance with the Louisiana Water Well Rules, Regulations, and Standards.;
7/25/2023	WATER WELL - NEW HOPE SITE	20SW17	GWR APPROVED CORRECTIVE ACTION PLAN	2/2/2024	LAC 51:XII.319.D.13 and 331.A - Abandoned water wells and well holes shall be plugged in accordance with the Louisiana Water Well Rules, Regulations, and Standards.;

+++++Environmental Protection Agency Required Health Effects Language+++++

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/CDC guidelines on appropriate means to lessen the risk of infection by Cryptosporidium and other microbial contaminants are available from the Safe Drinking Water Hotline (800-426-4791).

Additional Required Health Effects Language:

Some people who drink water containing trihalomethanes in excess of the MCL over many years may experience problems with their liver, kidneys, or central nervous systems, and may have an increased risk of getting cancer.

There are no additional required health effects violation notices.

+++++

Thank you for allowing us to continue providing your family with clean, quality water this year. In order to maintain a safe and dependable water supply we sometimes need to make improvements that will benefit all of our customers.

We at the CHATHAM WATER SYSTEM work around the clock to provide top quality drinking water to every tap. We ask that all our customers help us protect and conserve our water sources, which are the heart of our community, our way of life, and our children's future. Please call our office if you have questions.